GANDHI INSTITUTE OF ENGINEERING AND TECHNOLOGY UNIVERSITY, ODISHA, GUNUPUR

Permission Document for Connecting the Grid

GANDHI INSTITUTE OF ENGINEERING AND TECHNOLOGY UNIVERSITY, ODISHA, GUNUPUR

SOUTHCO UTILITY

Corp. Office: Courtpeta, Berhampur
E-MAIL: mrt.southco@southcoodisha.com

Letter No. 1478 (3) Dated 15/02/19

To
The Dy. General Manager (Elect.),
Electrical Circle, Rayagada.

Sub.: Regarding approval to connect Net meter / Bi-directional meter for 125KW solar Rooftop plant of GIET Campus under Gunupur Electrical Sub-division.

Ref.: 1) Y/O Ltr. No. 287 dt. 13.02.2018.

Sir,

With reference to the letter under reference, you are hereby allowed to ask the consumer Sri Satya Prakash Panda, GIET, Gunupur having existing consumer No. RYGD/3-0003 to procure a standard Net-metering / Bi-directional LTCT meter with 200/5A CT with meter box for availing power supply partially for the existing load from a 125KW Solar roof top Plant. After getting successful testing report from STL, Bhubaneswar, the same may be installed by complying the relevant Indian Standards; OERC order and CEA regulation under intimation to the undersigned.

Yours faithfully,

15/2/19

Sr. General Manager,
Corporate Office, SOUTHCO Utility,
Berhampur.

Copy Communicated to:

1) EE, GED, Gunupur.
2) EE, (MRT & EMR) Division, Rayagada.

Original with Ranik 16.02.19